

**CONSISTENCY DETERMINATION
SAN DIEGO INTERNATIONAL AIRPORT (SDIA)
AIRPORT LAND USE COMPATIBILITY PLAN (ALUCP)
MAY 5, 2011**

Item # 3 Resolution # 2011-0009 ALUC

Recommendation: Conditionally Consistent

**CONSTRUCTION OF 2 SINGLE-FAMILY RESIDENTIAL UNITS AT
4775 LONG BRANCH AVENUE, CITY OF SAN DIEGO**

Description of Project: Based on plans submitted to the ALUC, the project proposes the construction of two single-family residential units of 1,560 and 1,612 square feet with 2-car garages on two adjacent properties of 2,500 square feet each.

Noise Contours: The proposed project is located within the 65-70 decibel Community Noise Equivalent Level (dB CNEL) noise contour. (See the attached map.) The ALUCP identifies residential uses located within the 65-70 dB CNEL noise contour as conditionally compatible with airport uses, provided that the residences are sound attenuated to 45 dB CNEL interior noise level. The ALUCP requires that an aviation easement for aircraft noise and height be recorded with the County Recorder.

Airspace Protection Surfaces: The proposed project is located within the City of San Diego Airport Approach Overlay Zone (AAOZ). The maximum allowable height for a project on this site is approximately 400 feet Above Mean Sea Level (AMSL). The elevation of the site is approximately 34 feet AMSL and the structure is another 28 feet, resulting in a total project height of approximately 62 feet AMSL. Therefore, the project complies with the AAOZ.


Safety Zones: The proposed project is located outside the Runway Protection Zone (RPZ).

Ownership: The property is owned by Core Craft LLC, registered in California.

Recommendation: Based on review of the materials submitted in connection with the proposed project and the policies in the SDIA ALUCP, staff recommends that the ALUC make the determination that the project is conditionally consistent with the SDIA ALUCP.

Conditions: 1) Sound attenuation to an interior noise level of 45 dB CNEL.
2) Recordation of an aviation easement with the County Recorder.

000005



**4775 Long Branch Avenue
(APN: 448-423-27)**

0 0.125025 Miles

Legend

CNEL Contours

dB Level

- 60-65
- 65-70
- 70-75
- 75-80
- 80+
- RPZ

fwy
 majorrds
 roads

RESOLUTION NO. 2011-0009 ALUC

A RESOLUTION OF THE AIRPORT LAND USE COMMISSION FOR SAN DIEGO COUNTY MAKING A DETERMINATION THAT THE PROPOSED PROJECT: CONSTRUCTION OF 2 SINGLE-FAMILY RESIDENTIAL UNITS AT 4775 LONG BRANCH AVENUE, CITY OF SAN DIEGO, IS CONDITIONALLY CONSISTENT WITH THE SAN DIEGO INTERNATIONAL AIRPORT - AIRPORT LAND USE COMPATIBILITY PLAN.

WHEREAS, the Board of the San Diego County Regional Airport Authority, acting in its capacity as the Airport Land Use Commission (ALUC) for San Diego County, pursuant to Section 21670.3 of the Public Utilities Code, was requested by the City of San Diego to determine the consistency of a proposed development project: Construction of 2 Single-Family Residential Units at 4775 Long Branch Avenue, City of San Diego, which is located within the Airport Influence Area (AIA) for the San Diego International Airport (SDIA) Airport Land Use Compatibility Plan (ALUCP), originally adopted in 1992 and amended in 1994 and 2004; and

WHEREAS, the plans submitted to the ALUC for the proposed project indicate that it would involve the construction of two single-family residential units; and

WHEREAS, the proposed project would be located within the 65-70 decibel (dB) Community Noise Equivalent Level (CNEL) noise contour, and the ALUCP identifies residential uses located within the 65-70 dB CNEL noise contour as conditionally compatible with airport uses, provided that the project is sound attenuated to 45 dB CNEL interior noise levels, and that an avigation easement for aircraft noise and height is recorded with the County Recorder; and

WHEREAS, the proposed project is in compliance with the Airport Approach Overlay Zone (AAOZ) height restrictions; and

WHEREAS, the proposed project is located outside the Runway Protection Zone (RPZ); and

WHEREAS, the ALUC has considered the information provided by staff, including information in the staff report and other relevant material regarding the project; and

000007

WHEREAS, the ALUC has provided an opportunity for the City of San Diego and interested members of the public to present information regarding this matter;

NOW, THEREFORE, BE IT RESOLVED that the ALUC determines that the proposed project: Construction of 2 Single-Family Residential Units at 4775 Long Branch Avenue, City of San Diego, is conditionally consistent with the SDIA ALUCP, which was adopted in 1992 and amended in 1994 and 2004, based upon the following facts and findings:

- (1) The proposed project involves the construction of two single-family residential units.
- (2) The proposed project is located within the 65-70 dB CNEL noise contour. The ALUCP identifies residential uses located within the 65-70 dB CNEL noise contour as conditionally compatible with airport uses, provided that the project is sound attenuated to the 45 dB CNEL interior noise level. Therefore, as a condition of project approval, the project must be sound attenuated to the 45 dB CNEL interior noise level.
- (3) The ALUCP requires that an avigation easement for aircraft noise and height be recorded with the County Recorder for land uses for which sound attenuation is required. Therefore, as a condition of project approval, an avigation easement for aircraft noise and height must be recorded for the project with the County Recorder.
- (4) The proposed project is located within the AAOZ for the SDIA. The maximum allowable height for a project on this site is 400 feet AMSL. The maximum height of the proposed project is approximately 62 feet AMSL. The proposed project is therefore in compliance with the height limitations identified in the SDIA ALUCP.
- (5) The proposed project is located outside the RPZ.
- (6) Therefore, if the proposed project contains the above-required conditions, the proposed project would be consistent with the SDIA ALUCP.

BE IT FURTHER RESOLVED that this ALUC determination is not a "project" as defined by the California Environmental Quality Act (CEQA), Pub. Res. Code Section 21065, and is not a "development" as defined by the California Coastal Act, Pub. Res. Code Section 30106.

PASSED, ADOPTED AND APPROVED by the ALUC for San Diego County at a regular meeting this 5th day of May, 2011, by the following vote:

AYES: Commissioners:

NOES: Commissioners:

ABSENT: Commissioners:

ATTEST:

TONY R. RUSSELL
**DIRECTOR, CORPORATE SERVICES/
AUTHORITY CLERK**

APPROVED AS TO FORM:

BRETON K. LOBNER
GENERAL COUNSEL